



We Are Columbia

CITY OF COLUMBIA CROSS CONNECTION CONTROL PROGRAM
FIELD TESTING & MAINTENANCE REPORT FORM
FOR BACKFLOW PREVENTION DEVICES

ILLEGIBLE OR INCOMPLETE TEST REPORTS WILL NOT BE ACCEPTED

watercrossconnection@columbiasc.net or Office (803)545-3876

Date: _____

Account Name: _____

Account Address: _____

Account Number: _____ Meter Number: _____

Device Name: _____ Model Number: _____

Serial Number: _____ Size _____ Service Type: Fire Protection Domestic Irrigation

Device Location: _____

New Installation Replacement Existing (Annual) / ___ Serial Number Device being replaced _____

	Check No. 1	Check No. 2	Air-Inlet Or Relief Valve	# 1 Gate or Ball (Circle One)	#2 Gate or Ball (Circle One)
Test Before Repairs	(Mark One) Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> / _____	(Mark One) Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> / _____	Opened at _____ LBS. Differential Pressure _____	(Mark One) Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> / _____	(Mark One) Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> / _____
	Differential Pressure _____	Differential Pressure _____			
Repairs And New Materials					
Test After Repairs	(Mark One) Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> / _____	(Mark One) Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> / _____	Opened at _____ LBS. Differential Pressure _____	(Mark One) Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> / _____	(Mark One) Leaked <input type="checkbox"/> Closed Tight <input type="checkbox"/> / _____
	Differential Pressure _____	Differential Pressure _____			

Tester Name: _____

Tester Signature _____ Certification Number: _____

Company Name: _____ Company Telephone Number: _____

Method of Testing: Differential Pressure Test Kit Used: Mid-West 845

Comments: _____

(Mailing Address)
Columbia Water Cross Connections
4013 West Beltline Blvd. Columbia, SC 29204

ABOVE DATA CERTIFIED TO BE CORRECT
watercrossconnection@columbiasc.net or Office (803)545-3876